

GOVERNMENT OF ANDHRA PRADESH
FIRE PREVENTION WING, MUNICIPAL CORPORATION, TIRUPATI.
FIRE NO OBJECTION CERTIFICATE

From: Regional fire Officer,
Fire Prevention Wing
Municipal Corporation,
Tirupati.

To: The District Educational Officer,
Chittoor,
Chittoor District.

Rc.No: 45/FPW/MCT/2022, Dated: 22.12.2022.

Sir,

Sub : Municipal Corporation – Fire Prevention Wing – Existing Non Multi Storeyed building of Silver Bells Central School, D.No:19-3-2/G10,Srinivasa Puram,Telugu Nagar, Tirupati –Fire No Objection Certificate for Occupancy - Issued.

- Ref:
1. Memo. No: 12323/M1/2009 of MA & UD (M) Dated: 06.04.2010 and Letter Rc.No:5041/B2/97 of The Director General, A.P. State Disaster Response & Fire Services Department, A.P., Hyderabad. Dated: 12-03-2010.
 2. G.O.Ms. No:154 MA&UD Dept Dt:13.03.2007, G.O.Ms 179 MA&UD Dept DT:21.08.2015.&G.O.Ms. No:119 MA&UD Dept Dt:28.03.2017
 3. Application No: Nil, Dated:26.06.2019 of Silver Bells Central School, D.No:19-3-2/G10,Srinivasa Puram,Telugu Nagar, Tirupati.
Inspection Report Rc.No:45/FPW /MCT/2019, Dated: 29.06.2019.
 5. E Office File No: E.235084 Dt:01.07.2019 of The Commissioner, Municipal Corporation, Tirupati.

@@@

Under the powers delegated vide references 1st cited, The officers from the Fire Prevention Wing, Municipal Corporation, Tirupati have inspected the existing building premises of Silver Bells Central School, D.No:19-3-2/G10,Srinivasa Puram,Telugu Nagar, Tirupati on 29.06.2019.

2. The existing Non Multi Storied building consisting of Ground Floor only with a height of 03.00 Metres for Educational Occupancy (B). The Management has not obtained provisional Fire No Objection Certificate and now the management applied for Fire No Objection Certificate for Occupancy to their existing building.

3. Particulars of the existing building:-

a.	Address of the building	Silver Bells Central School, D.No:19-3-2/G10,Srinivasa Puram, Telugu Nagar, Tirupati
b.	Plot area/Height of the Building	4419.82 Sq. Mtrs./3.00Mtrs
c.	No of blocks / floors	One /Ground Floor only
d.	Type of occupancy	Educational Occupancy (B).

Continued in Page.2

Manjamma
MANJAMMA
PRINCIPAL
SILVER BELLS CENTRAL SCHOOL

V. M. S.
SECRETARY
SILVER BELLS CENTRAL SCHOOL
TIRUPATHI

:: 2::

4. Fee Particulars:

Sl.No	Fee Details	Challan No. & Date	Amount	Remarks
1.	Fire Precautionary Fee & Occupancy fee	Rs:27,600/-vide ChallanNo:06/2019-20/dated: 26.08.2019 at Municipal Treasury, Tirupati.	Rs: 27,600/-	--
Total			Rs:27,600/-	

5. Floor Wise Details:

Sl.No.	No.of Floor	Area in Sq. Meters	Occupancy	Occupant Load as Per Table -3,Part -4,NBC-2016
1.	Ground only	1444.77	Educational	362
Total		1444.77	-	-

6.The Minimum Fire Safety Installations provided by the Management as per Part IV, Table 7 of NBC 2016.:

Sl.No	Fire Safety Measures	Required	Provided	Deficit
1.	Fire Extinguishers as per IS 2190	15 Nos.	15 Nos.	Nil

7. In View of the above, the Fire No Objection Certificate for occupancy is hereby issued to Silver Bells Central School, D.No:19-3-2/G10,Srinivasa Puram,Telugu Nagar, Tirupati subject to the following Conditions:

- The NOC issued is confined to the Fire Safety measures installed in the building and does not confer any Legal right for claiming of Ownership of property or Conversion of land use/Occupancy or Building Regularization. The Owner/ Occupier shall comply the Building Rules/Govt. Orders as applicable. This is without any prejudice to the action taken by MCT against Unauthorized Construction, if any.
- Evacuation plan showing exit routes and recommended action plan shall be displayed at conspicuous locations and shall be exhibited at all times, all escape /exit routes shall not be blocked or encroached.
- Fresh NOC would be required for any change in occupancy as per NBC and building Bye laws
- The management has to maintain Fire Safety Measures at all times in good working Condition as seen during the time of inspection.

Mangir K.N.

PRINCIPAL
SILVER BELLS CENTRAL SCHOOL
TIRUPATI

V.M. Sankar

SECRETARY
SILVER BELLS CENTRAL SCHOOL
TIRUPATHI


Continued in Page.3

:: 3::

- e. Any Loss of life or property due to Non-functioning of Fire Safety Measures and other installations shall be the responsibility of the management/owner.
 - f. All the Occupants must know the correct method of operation of the Fire Fighting System installed.
 - g. All occupants/security personnel shall be trained to operate the Fire safety Equipment during the Emergency.
 - h. The Fire Drills shall be conducted once in every three months for first two years.
9. This is valid for a period of one year from the date of issue. It is the responsibility of the builder/Occupier to apply for renewal of Fire NOC before two months of expiry of this certificate.

(Under Orders of the Commissioner, Municipal Corporation, Tirupati).




(R.GNANASUNDARAM)
Regional Fire Officer,
Fire Prevention Wing,
Municipal Corporation, Tirupati.

- Copy to the Management/Principal of Silver Bells Central School, D.No:19-3-2/G10,Srinivasa Puram,Telugu Nagar, Tirupati.
- Copy submitted to the Commissioner, MC, Tirupati.


PRINCIPAL
SILVER BELLS CENTRAL SCHOOL
TIRUPATI


SECRETARY
SILVER BELLS CENTRAL SCHOOL
TIRUPATHI